



Product Service

CERTIFICATE

No. Z2 103237 0011 Rev. 00

Holder of Certificate: **CSUNPOWER Technology (Nanjing) Co., Ltd**
10F, Building B4
No.19, Suyuan Avenue, Jiangning District
211106 Nanjing
PEOPLE'S REPUBLIC OF CHINA

Certification Mark:



Product: **Crystalline Silicon Terrestrial Photovoltaic (PV) Modules**
Mono-Crystalline Silicon Photovoltaic Module

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition, the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the testing and certification regulations of TÜV SÜD Group have to be complied. For details see: www.tuvsud.com/ps-cert

Test report no.: 704062122704-00

Valid until: 2026-09-09

Date, 2021-09-10

(Zhulin Zhang)

ZERTIFIKAT ◆ CERTIFICATE ◆ 認證證書 ◆ CERTIFICADO ◆ CERTIFIKAT ◆ CERTIFICATE



CERTIFICATE

No. Z2 103237 0011 Rev. 00

Model(s):

CP21-66HTXXXW, xxx=635-665 in step of 5
 CP21-60HTXXXW, xxx=580-605 in step of 5
 CP18-72HTXXXW, xxx=525-550 in step of 5
 CP18-66HTXXXW, xxx=485-500 in step of 5
 CP18-60HTXXXW, xxx=440-455 in step of 5
 CP17-72HTXXXW, xxx=425-455 in step of 5
 CP17-60HTXXXW, xxx=355-375 in step of 5
 xxx is standing for rated output power at STC

Parameters:

Construction:	Framed, with Junction box, Cable and Connectors.
Safety Class:	Class II
Maximum System Voltage:	1500 V DC
Fire Safety Class:	Class C according to UL790
Severity of Salt mist test:	Test method 6

Tested according to:

IEC 61215-1:2016
 IEC 61215-1-1:2016
 IEC 61215-2:2016
 IEC 61730-1:2016
 IEC 61730-2:2016
 IEC 61701:2020